


### Fire, Smoke and Exit Doors

Encompassed in the Path of Travel inspection is an inspection of all Fire/Smoke and Exit doors of the property. Fire/Smoke doors are required to be inspected on a regular basis with the frequency outlined in the Occupancy Permit.

Fire/Smoke doors are designed to provide protection by reducing the spread of fire and smoke, and allow a safe path of egress from the building. Fire Doors actively contain a fire so the structure can remain fire-resistant for a period of time, enabling occupants to safely exit the building in case of emergency.



The technician does a visual inspection of the fire, smoke and exit doors throughout the property. The technician is looking out for any damage or changes to the door, whether the door closer is present and working as designed, whether there are smoke seals on the frame and intact, whether the door is latching and staying closed as required and also whether the door is being obstructed or held open.